

OFFICE OF THE EXECUTIVE ENGINEER, RURAL WATER SUPPLY & SANITATION
DIVISION GAJAPATI, PARALAKHEMUNDI, Ph. 06815 224803, email-
eerwssgjp@gmail.com

Letter No:-

2054

Dated:- 16-07-2021

To,

The Principal

Kendriya Vidyalaya, Gajapati.

Sub:- Submission of water testing report of your school.

Sir,

With reference to the aforesaid subject, I am submitting herewith the test report of 1 No of water sample of your school.

This is for information and necessary action.

Encl:- As above one sheet

Yours Faithfully,

Jash
16.7.21


Executive Engineer, RWS&S
Division, Gajapati

16-07-21


REPORT ON WATER QUALITY AND SURVEILLANCE

Name of Division:-Gajapati		Source wise Water Quality Parameters Value in PPM											
		Iron	Fluoride	Chloride	Alkalinity	Hardness	Ph-Value	TDS	Conductivity	Colour	Odour	Bacteria	
Sl No	Name of the School	Location & Type of the source	(<1.00)	(<1.50)	(<1000)	(<600)	(<600)	(6.5- 8.5)	(<2000)				
1	Kendrya Vidyalaya Gajapati	School inside PW	0.13	0.24	40	100	112	6.91	188	116.00	Colourless	Odourless	Absent

The test results on the water samples is found that the parameters like Iron, Fluoride, Chloride, Alkalinity, Hardness, Ph value, TDS, and Bacteria etc. are in permissible limit. So, the water is safe for human consumption.


 Lab Chemist, RWSS
 Division, Gajapati


 Jr. Lab Assistant RWSS
 Division, Gajapati


 Executive Engineer, RWSS
 Division, Gajapati